



CITY of DODGEVILLE

100 E. FOUNTAIN STREET
DODGEVILLE, WI 53533

CLERK-TREASURER (608) 935-5228
PUBLIC WORKS DIRECTOR (608) 935-0496
BUILDING INSPECTOR/ASSESSOR (608) 935-9326
CITY ATTORNEY (608) 935-2548
FAX NUMBER (608) 935-3520

COPY

Home of Wisconsin's Oldest Courthouse

March 20, 2003

Lands' End, Inc.
Mr. Gary Lodahl
2 Lands' End Lane
Dodgeville, WI 53595

RE: Renegade Parts Washer

Dear Mr. Lodahl:

I have reviewed your request to discharge waste from the Renegade Parts washer into the City of Dodgeville Sanitary Sewer System. The City will allow Lands' End to discharge waste from the Renegade Parts washer into the City Sanitary System, with the following conditions:

1. The discharge shall be in compliance with the City of Dodgeville's Sewer Use ordinance.
2. The discharge is granted only to Lands' End, Inc. and shall be limited to a maximum of 50 gallons each 3 months and said 50 gallons shall be bled into the sewer system over a period of not less than 24 hours.

3. The City reserves the right to sample the discharge and terminate the discharge of this waste if problems with the treatment of the waste occur at the City of Dodgeville's Wastewater Treatment Facility.
4. The City's decision is based on the contents of the "submittal package" provided to the City of Dodgeville by Renegade, and the accuracy of the material contained therein.

Please call if you have any questions or comments.

Sincerely,



Michael A. Bisbach, P.E.
City Engineer