

**MADISON METROPOLITAN
SEWERAGE DISTRICT**

1610 Moorland Road
Madison, WI 53713-3398
Telephone (608) 222-1201
Fax (608) 222-2703

Jon W. Schellpfeffer
Chief Engineer & Director



COMMISSIONERS

Edward V. Schten
President
Thomas D. Hovel
Vice President
P. Mac Berthouex
Secretary
Caryl E. Terrell
Commissioner
John E. Hendrick
Commissioner

July 27, 2005

Ms. Joleen Kokenzie
Service Line, Inc.
2320 Zinga Drive
Reedsburg, WI 53939

Dear Ms. Kokenzie:

In the absence of Ralph Erickson, I am responding to your request to discharge liquid from a Renegade Parts Washer to be used by the City of Madison. As Ralph had indicated in his email, some of the sample data you showed us from other communities had cadmium concentrations greater than our Sewer Use Ordinance limit of 0.25 mg/l. You then operated the unit in Madison and analyzed a sample of the liquid that would need to be discharged. The analytical results of that sample collected on May 10, 2005, showed that the concentrations of all of the parameters for which it was analyzed were below the limits of the District's Sewer Use Ordinance.

At this time we will approve the discharge of spent aqueous parts cleaning solutions from your unit by the City of Madison. Please ensure that the City personnel responsible for the unit contact Ralph when they are ready to discharge liquid from the unit. We will want them to collect a sample and have it analyzed for the same parameters for which it was analyzed in the past. If the results of the analysis would indicate that Sewer Use Ordinance limits were exceeded, we would require analysis of additional samples to show that the discharge is in compliance with the limits.

Sincerely,

Paul H. Nehm
Director of Operations and Maintenance

cc: Ralph Erickson

