

# City of Mason

201 W. Ash St.  
P.O. Box 370  
Mason, MI 48854-0370  
www.mason-mi.us



City Hall 517 676-9155  
Police 517 676-2458  
Fax 517 676-1330  
TDD 1-800-649-3777

August 25, 2006


Ms. Jessica Wilcox  
Service Line Inc.  
2320 Zinga Drive  
Reedsburg, WI 53959

Dear Ms. Wilcox,

I received the analytical data for the Renegade parts washer from Service Line Inc. Upon review of the results from this one test, it appears the discharge from the washer meets the City of Mason discharge requirements. However as you pointed out in your letter the City of Mason requires a lower detection level for silver than was used. In order for me to give a more definitive answer more analytical data would be needed. It should also be pointed out the City of Mason discharge requirements may change as state and federal regulations become more restrictive.

The City of Mason does have an Industrial Pretreatment Program. This program would require Service Line Inc. to complete a Non-Domestic User Survey. The survey would be provided upon request.

Sincerely,

  
Jim King, Plant Superintendent  
Mason P.O.T.W. Plant