

10545 Armstrong Avenue

June 26, 2006

Mather, CA 95655

Tele: [916] 876-6000

Fax: [916] 876-6160

Website: www.srcsd.com

Jessie Wilcox Service Line, Inc. 2320 Zinga Dr Reedsburg, WI 53959

Board of Directors

Representing:

County of Sacramento

County of Yolo

City of Citrus Heights

City of Elk Grove

City of Folsom

City of Rancho Cordova

City of Sacramento

City of West Sacramento

Mary K. Snyder District Engineer

Stan R. Dean Plant Manager

Wendell H. Kido District Manager

Marcia Maurer Chief Financial Officer SUBJECT:

RENEGADE PARTS WASHER & SEWER USE

QUESTIONNAIRE

Your Material Safety Data Sheet for Renegade Cleaner/Degreaser has been received and reviewed by the Sacramento Regional County Sanitation District (SRCSD). Based on the information submitted, we have the following requirements for disposal of parts washer wastewater.

- Businesses discharging process wastewater into the SRCSD sewer system must file a Sewer Use Questionnaire. The completed Sewer Use Questionnaire is a declaration of wastes discharged into the sanitary sewer system and will be kept on file with the Wastewater Source Control Section. A business is authorized to discharge wastewater as described in the subject questionnaire into the SRCSD sewer system in accordance with the ordinances and rules of SRCSD and its contributing agencies. A business is responsible for furnishing an updated Sewer Use Questionnaire if there is a significant change to the wastewater discharge that has not been previously declared or if SRCSD requests a new questionnaire.
- Wastewater discharges must meet the requirements of the SRCSD Sewer Use Ordinance. For example, pH must be above 5 and below 12.5, no flammable or hazardous substances may discharged, and Oil & Grease of petroleum origin must be less than 100 parts per million.

Thank you for cooperation. Please call me at 876-5287 if you have any questions.

Respectfully,

Linda Cochran

Environmental Specialist

Wastewater Source Control Section